



Clint Coiment
Parish President

PARISH OF ASCENSION

PURCHASING

615 E Worthey Rd.
Gonzales, LA. 70737
(225) 450-1200
www.ascensionparish.net

Addendum No. 5

Date: April 30, 2024

PURPOSE: Addendum No. 5- Extension of Bid, Unit Price Form Uploaded, Questions and Answers Posted

BID NOTICE

Sealed bids will be received by Ascension Parish Government at the Ascension Parish Government Purchasing Office, 615 E. Worthey Street, Gonzales, Louisiana 70737 (mailing address PO Box 2392, Gonzales, LA 70707-2392) until ~~May 2, 2024, at 10:00 a.m.~~ **May 9, 2024 at 10:00 am** local time. The bids will be publicly opened and read aloud for the following:

Asphalt Concrete Reconstruction & Overlay Improvements (Indefinite Delivery/ Indefinite Quantity Contract) 2024

- Ref No. 33 Asphalt Concrete Pavement Widening (page 16) does not show a thickness. On the previous bid forms, the depth was called out as 9". Please provide a definitive depth for patching.

Specifications state the depth is 9"

- Ref Nos. 25-27 (pages 12 & 13) are all vehicular measurement items, but the unit of measure on the bid form was changed to SY. The unit for these items needs to be changed back to CY.

All 02401 items should have the quantity of CY.

- We need to have a lime percentage to bid on. I agree that the percentage can be adjusted on a case by case basis but the contractor cannot assume the percentage for bidding purposes. What is to stop a contractor from assuming 2% to reduce their bid price? How will the owner know what percentage the contractor assumed using as a baseline for adjustments?

Specifications state the lime quantity is 25 lbs per square yard.

- **Revised Version of the Unit Price Form has been Uploaded.**