

ADG Baton Rouge, LLC

3071 Teddy Drive
Baton Rouge, LA 70809
225.293.9474



December 7, 2020

Animal Shelter Replacement
Sorrento, Louisiana
Ascension Parish Project No. PM-06-009
ADG Baton Rouge Project No. 20-202

ADDENDUM #4

The following items shall be considered part of the Contract Documents for the above referenced project and shall take precedence over any conflicting statements contained therein. Revise all other notes, schedules, details, elevations, and sections as required.

ELECTRICAL CLARIFICATIONS:

1. Contractor shall run the feeder for new panel "LB" underground. Cut and patch the existing concrete as required.

MECHANICAL CLARIFICATIONS:

1. The Trash trap indicated on the plumbing drawings shall be Gainey's model GCP 1000TT-NT or approved equal.

If you have any questions, please contact our office.

ADG Baton Rouge, LLC
A Professional Engineering Company